

Spent Fuel Management and Storage in Korea

2010. 11. 15

Jongwon CHOI




**Korea Atomic Energy
Research Institute**

Contents

- **Spent Fuel Management**
 - ✓ **NPP & SF Status**
 - ✓ **Policy**
 - ✓ **Storage**

- **R&D Activities for Dry Storage**
 - ✓ **Storage System**
 - ✓ **Spent Fuel Integrity**


Nuclear Power Plant in Korea



Units (MWe), As of Oct. 2010


Site	In Operation	Under Construction	Total
Kori	4 (3,137)	4 (4,800)	8 (7,937)
Wolsong	4 (2,779)	2 (2,000)	6 (4,779)
Yonggwang	6 (5,900)	-	6 (5,900)
Ulchin	6 (5,900)	2 (2,400)	8 (8,300)
Total	20 (17,716)	8 (9,200)	28 (24,516)

❖ ~10 NPPs will be added in 2030.




Spent Fuel Amount

SF Amount



Annual arising : 700 tU/Yr



NPP Site	Capacity (ton)	Accu. (ton)	Expected Saturation (year)
Kori	2,190	1,784	2016
Yonggwang	2,670	1,753	2016
Ulchin	2,350	1,449	2017
Wolsong	9,440	5,886	2018
Sum	16,650	10,872	-

National Policy for RadWaste

253rd AEC's Decision (Dec. 2004)


- ◆ Final repository for LILW should be constructed by 2008. → Delayed until 2012 for Safety Reason
- ◆ Spent Fuel Management
 - All spent fuel will be stored at plant sites until 2016.
 - Future national policy for SF management will be decided through public participation taking into consideration of national and international trends on policy and technology development.

RadWaste Management Act


- This Act has been effective since January 1st, 2009.
- Key contents are:
 - Establish. of a new Org., responsible body for radwaste management
 - Korea Radioactive Waste Management Corporation (KRMC)
 - Establish. of the Radioactive Waste Management Fund
 - which will be paid by the Radwaste generator.
 - KRMC is responsible for managing the RadWaste Fund

Organization related with RadWaste Management

6



Overall Plan for Radwaste Management



Spent Fuel Storage at NPP

* As of Dec. 2009 (Unit : MtU)

Plant Site	Capacity	Yr of Saturation	Accum.
Kori	2,253	2016	1,685
Yong-gwang	2,686	2016	1,623
Ulchin	2,327	2017	1,294
Wolsong	5,980(9,440)	2018	5,481
Total	13,246		10,083

- ◆ To secure the on-site storage capacity
 - PWR's storage facility has been expanded by re-racking and transshipment.
 - CANDU SFs have been transferred to the dry storage facility (concrete silo) since 1991

◆ Kori

- Unit 1 : Transshipment to Units 3&4
- Unit 3&4 : Addition of high density racks

◆ Ul chin


- Unit 1&2 : Full re-racking of AR pool

◆ Young kwang

- Unit 1 : Transshipment to Units 3&4

◆ Wol song

- Unit 1 : 300 Concrete silos for 162,000 bundles




Expansion of Storage Capacity

PHWR(CANDU) SF



- ① Concrete Silo
- ② MACSTOR/KN-400

PWR SF



High Density Reracking



Transshipment between NPPs


Concrete Silo for CANDU SF Storage

10

- **Concrete Silo System**


- ✓ Capacity: 540 Bundle (60 Bundle/Basket x 9 Basket)
- ✓ Out Diameter: 3.07 m
- ✓ Height: 6.52 m

- **Total 300 Silos (~3,200 MtU) installed from 1990**




MACSTOR/KN-400 for CANDU SF Storage

11



• High-dry Storage Facility

- ✓ 7 modules at Wolsong site (2010)
- ✓ Economy : reduce of Area by 2.7 times compared to concrete silo
- ✓ Cooling: Passive Natural Cooling



Design Parameters of MACSTOR/KN-400

Storage System	
Lifetime	50 years
Temp. Limit in operation	66 °C
KN-400 system	24,000 bundles
	System: 40 cylinders
	Cylinder : 10 baskets
	Basket : 60 bundles
5,000 Bundles generation in a PWHR / year 24,000 bundles = 1.2 x All SF generation in 4 PHWR in a year = 44.4 x Silo dry storage	
Dimension	22 (L) x 12.5 (W) x 7.5 (H) m
Structure Material	Reinforced Concrete
Thickness	Side : 0.98 m Top : 1.08 m



PHWR Spent Fuel	
Cooling Time	Minimum 6 years
Average Burnup	7,800 MWd/MtU
Average Heat Flux	6.08 Watt
Initial U mass	19.2 kgU / Bundle
Bundle Max. Temp in dry storage	168 °C

SF transshipment between NPPs

Transshipment	Year	No. of Spent fuels	Transfer Cask
Kori 1→Kori 3	1990-2004	424	KSC-4
Kori 1→Kori 4	1994-2004	188	KSC-4, KN-12
Kori 2→Kori 4	2000	12	KN-12
Kori 2→Kori 3	2001-2004	244	KSC-4, KN-12
Kori 4→Kori 3	2004	60	KN-12
Total		928	

- Total 928 assemblies moved to neighboring units between 1990-2004.

Contents

- **Spent Fuel Management**
 - ✓ NPP & SF Status
 - ✓ Policy
 - ✓ Storage


- **R&D Activities for Dry Storage**
 - ✓ Storage System
 - ✓ Spent Fuel Integrity

Backgrounds of SF Dry Storage


15

- ◆ **ISFSF should be in commission by 2016**
- ◆ **Some prerequisites for dry storage (to be considered)**
 - Integral spent fuel history & properties database
 - : new fuel design, increased burnup due to improved op. tech.
 - Thermal cycling limitation due to to in-site transshipment for expansion of the on-site storage capacity
 - Technical criteria for safe dry storage system such as the long-term integrity of SF and storage facility material

Storage System Develop. Plan



Fuel Environ. Change



Fuel Supply History in Korea

Plant \ Year	1990	1995	2000	2005	2010		
Kori-1 (WH14)		KOFA	OFA				
Kori-2 (WH16)	KOFA	STD				ACE7	
Kori-3/4 (WH17)		KOFA	V5H	RFA		ACE7	
YGN-1/2 (WH17)		KOFA	V5H	RFA		ACE7	
UCN-1/2 (WH17)		KOFA	V5H	RFA		ACE7	
S-UCN-1/2(APR)						Guardian	PLUS7
YGN-3/4 (OPR)		OPR		Guardian	PLUS7		
YGN-5/6 (OPR)			OPR	Guardian	PLUS7		
UCN-3/4 (OPR)			OPR	Guardian	PLUS7		
UCN-5/6 (OPR)				Guardian	PLUS7		
S-KR-1/2 (OPR)						Guardian	PLUS7
S-KR-3/4 (APR)							PLUS7
Wolsong(CANDU)			STD CANDU				
S- Wolsong (OPR)						Guardian	PLUS7


KOFA : Korean FA, OFA : W's Optimized FA, STD : W's Standard FA

V5H : Vantage5H FA, RFA : Robust FA, **NGF** : **Next Generation FA**


OPR : OPR FA, Guardian : OPR FA with Debris Filtering Grid, **PLUS7** : **Advanced OPR FA**,

STD CANDU : Standard CANDU Fuel Bundle

Capacity Factor in Korea



1984 ~ 1994




1998 ~ 2007

Source: Ministry of Knowledge and Economy
2008 Nuclear Power Note



Discharge Burnup Increase

■ Discharge Burnup Increase as longer NPP operating cycle




■ Current average discharge burnup : 45 GWd/MTU

■ 4.5 wt.% enriched spent fuels from 2010 with average 55GWd/MTU burnup




Spent Fuel DB (1/2)

❖ SNF DB : planed tracing system on ID basis




Spent Fuel DB (2/2)

❖ SNF DB Module Structure




Tech. Roadmap for SF Integrity study

Objective Technology development for the dry-stored SF integrity evaluation




Objects of the Study

Spent Fuel



Structural Components



To develop reference degradation mechanism model under SF characteristics and storage condition

Target

- ① Developing prototype model
- ② Evaluating SF structural deformation
- ③ Analyzing previous SF test data
- ④ Developing integrity evaluation code system

Product

- Patent/report/article for degradation models
- Integrity evaluation code design and model PIRT
(Phenomena Identification and Ranking Table)

To develop hot-test scenario of 2nd Phase experiments

Target

- ① Characterization test scenario of SF
- ② Unit test scenario of SF
- ③ Integrated test scenario of SF


Product

- Conceptual design of unit test experiments
- Patent application for conceptual design
- Scenarios for Char./Unit/Integrated test

Major Degradation Mechanisms


Clad Degradation

- **Creep Rupture**
- Hydrogen re-orientation
- Delayed Hydride Cracking
- Oxidation
- Stress Corrosion Cracking
- Diffusion Controlled Cavity Growth




Pellet Degradation

- Oxidation
- Fragmentation



Characteriz. Test of SF in PIEF



Characteriz. Test of SF in PIEF

Design type			Westinghouse type											OPR			Sum	
Array type			14X14			16X16				17X17				16X16				
Fuel Name			STD	KOFA	OFA	STD	KOFA	STD	6ACE	OFA	KOFA	V5H	RFA	17ACE	KSNP	Guardian		PLUS7
Own	Assembly	Owned Assembly	6	-	-	-	1	-	-	-	-	1	-	-	-	-	-	8
		Enrich (U-235 wt %)	2.1~3.2				3.5					4.2						
		Burnup (GWd/tU)	17~38				35					53						
		Cladding	Zry-4				Zry-4					Imp. Zry-4						
	Rod	Owned Rods	-	-	-	-	-	9	-	-	3	16	6	-	2	6	10	52
		Enrich (U-235 wt %)						3.8			3.8	4.2~4.49	2.61~4.51		2.3~3.4	4.49	4.49	
		Burnup (GWd/tU)						32~42			7~12	40~56	34~54		1.8~2	48~55	55~58	
		Cladding						Zry-4			Low Tin Zry-4	Adv. Zry-4 Zirlo	Zirlo		Zry-4	Zirlo	Zirlo	
Charac terizati on Test	NDT	Visual Test	19	-	-	-	8	9	-	-	3	22	4	-	2	6	3	76
		Dimension Measure	19	-	-	-	8	9	-	-	3	17	4	-	2	2	3	67
		ECT	19	-	-	-	8	9	-	-	3	21	4	-	2	6	3	75
		γ-spectroscopy	19	-	-	-	8	9	-	-	3	21	4	-	2	6	3	75
	DT	Rod Internal Pressure/FGR Measure	13	-	-	-	2	6	-	-	2	16	2	-	0	2	2	45
		Ceramography/Metallography	13	-	-	-	2	7	-	-	2	20	2	-	2	2	3	53
		Chem. Analy(Burnup,Hydroge)	13	-	-	-	2	7	-	-	2	19	2	-	0	2	2	49
		Pellet/Clad Material Properties	13	-	-	-	2	7	-	-	2	9	2	-	2	2	2	41

Conclusions

- **Long-term SF management program will be established through public engagement.**
- **For mid-term policy of SF management, interim SF storage facility will be in operation by 2016**
- **Since June 1st in 2009, we have started R&Ds on SF Integrity Study.**
- **Integrity Evaluation Code and Indigenous test data will be expected.**

Thank you



